

PUBLIC/PRIVATE SCHOOL

STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC/PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.721016/-80.305559

- PURPOSE:**
- ROUTINE
 - CONSTRUCT.
 - COMPLAINT
 - QA SURVEY
 - OTHER
 - REINSPECTION
 - CHANGE OF OWNER
 - CONSULTATION
 - EPIDEMIOLOGY
 - PREOPENING

TYPE: Public School

CENSUS	FEMALES	MALES
2249	1078	1171

NAME South Miami Senior High Annex

ADDRESS 6856 SW 53 Street **CITY** Miami

OWNER M-DCSB Food and Nutrition **ZIP** 33155

PERSON IN CHARGE Gilberto D. Ponce **PHONE** (305) 666-5871

E-MAIL cneilly@dadeschools.net

RESULTS:

- Satisfactory
- Incomplete
- Unsatisfactory
- OUT OF BUSINESS

Correct Violations by

- Next Inspection
- 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
10:20	12:30	04/06/2015	27455	13-51-14508

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

- | | | | |
|---|---|--|--|
| <p>SCHOOL SANITATION</p> <ul style="list-style-type: none"> <input type="checkbox"/> 1. School Site <input type="checkbox"/> 2. Playground Equipment <input type="checkbox"/> 3. Athletic Equipment <p>BUILDINGS</p> <ul style="list-style-type: none"> <input type="checkbox"/> 4. Construction <input checked="" type="checkbox"/> 5. Maintenance & Repair <input type="checkbox"/> 6. Lighting/Foot-Candles <input type="checkbox"/> 7. Heating, Ventilation, A/C | <ul style="list-style-type: none"> <input type="checkbox"/> 8. Natural Ventilation <input type="checkbox"/> 9. Mechanical Ventilation <input type="checkbox"/> 10. Provided/Accessible <input type="checkbox"/> 11. Cleanliness & Repair <input checked="" type="checkbox"/> 12. Toilet Facilities <input type="checkbox"/> 13. Separation of Sexes <input type="checkbox"/> 14. Fixture Ratio <p style="text-align: center;">SANITARY FACILITIES</p> <p style="text-align: center;">WATER SUPPLY</p> <ul style="list-style-type: none"> <input type="checkbox"/> 15. Handwash Facilities <input type="checkbox"/> 16. Showers/Fixtures <input type="checkbox"/> 17. Shower Water Temp. <input type="checkbox"/> 18. Installed/Operated/Maintained <input checked="" type="checkbox"/> 19. Drinking Fountains <input type="checkbox"/> 20. Approved Source | <p style="text-align: center;">LIQUID/SOLID WASTE</p> <ul style="list-style-type: none"> <input type="checkbox"/> 21. Sewage Disposal <input type="checkbox"/> 22. Solid Waste <p style="text-align: center;">VECTOR/VERMIN CONTROL</p> <ul style="list-style-type: none"> <input type="checkbox"/> 23. Infestation/Control <input type="checkbox"/> 24. Brush/Trash <input type="checkbox"/> 25. Water Collection/Drainage | <p style="text-align: center;">SAFETY</p> <ul style="list-style-type: none"> <input type="checkbox"/> 26. First Aid Kit <p style="text-align: center;">FOOD</p> <ul style="list-style-type: none"> <input type="checkbox"/> 27. Food Insp. Rpt. <p style="text-align: center;">OTHER</p> <ul style="list-style-type: none"> <input type="checkbox"/> 28. <input type="checkbox"/> 29. |
|---|---|--|--|

COMMENTS AND INSTRUCTIONS

Violation #5 Repair exhausted fan in the bathroom # 602 and 605.
Code Reference FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Violation #12 Replace broken toilet seat in girls bath # 501
Code Reference FAC: Toilet Facilities 64E-13.004(6)(a). Toilet facilities shall be accessible under continuous roof cover from all student occupied spaces. In group toilet rooms a partition shall be placed between each water closet. Each compartment shall have a door. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block the occupants from view. Entrance doors shall be self-closing.

Violation #15 Repair missing knog in the handwash inside room #504.
Violation #15 Repair faucet with no water in girls bath #501
Violation #15 Replace missing toilet paper dispenser in boys bath room # 414
Violation #15 Unclog one of the soap dispenser inside girls bath #411
Code Reference FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of

Continued On Page 2

INSPECTION CONDUCTED BY: Zenaida Triana **PHONE:** (305) 623-3500 ex.

INSPECTION COND SIGNATURE: Zenaida Triana **PHONE 2:** 786-216-9837

COPY OF REPORT RECEIVED BY: x CNB **DATE:** 4/6/2015

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY PUBLIC HEALTH UNIT
Public/Private School



Name: South Miami Senior High Annex

Date: 04/06/2015

Identification No: 13-51-14508

Comments and Instructions (Continued from Page 1):

common or public towels is prohibited. Hot-air hand drying devices

Violation #19 Repair water fountains with no water in front rooms #501-504

Violation #19 Repair water fountain with broken handle by room #608.

Violation #19 Repair the 3 water fountains in front bath #414.

Code Reference FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Copy of Report
Received By:

Inspector Zenaida Triana

Page 2